

THOMPSON DYKE & ASSOCIATES, LTD.

Land Planning
Landscape Architecture
Urban Planning

Date: September 12, 2011
To: Plan Holders
From: Liz Dafoe 989.992.2238
Thompson Dyke & Associates, Ltd.
Subject: Addendum No. 1 to the Project Manual and Construction Drawings for the
Lakefront Park Glencoe Beach Improvements



This Addendum consists of 2 pages.

This addendum forms a part of and modifies amends and clarifies the bidding requirements and the contract documents for the above project. All provisions of the original requirements and documents shall remain in force, except as specifically changed herein, or by other addenda.

Receipt of this Addendum shall be acknowledged on the bid form in the space provided. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

Addendum items

- Item 1** **Clarification** – The existing water service line at Glencoe Beach is 1 1/2” copper line. From the manifold there are 5/8” buried heavy duty hoses that runs under the sand to each of the water play pieces. These hoses are existing and the new play equipment shall be connected to the existing lines. The existing valves are brass any repair or replacements shall be same.
- Item 2** **Clarification** – *On sheet D1.0, detail H shows a by-pass for the manifold, is this existing? or does it need to be installed?* The bypass for the RPZ showing is existing. The RPZ is to be replaced. The bypass that is shown to the proposed water odyssey manifold does not exist and shall be installed.

THOMPSON DYKE & ASSOCIATES, LTD.

Land Planning
Landscape Architecture
Urban Planning

The foregoing addendum is accepted hereby as an essential part of the contract for the above entitled work.

Name of Bidder: _____

By: _____
(Signature)

Title: _____

Date: _____

NOTE: RETURN THIS ADDENDUM (FULLY SIGNED AND DATED) WITH BID.

END OF ADDENDUM NO. 1
DATE: September 12, 2011